





Model DAWN-4"-DOOR[®] Curved Slats Rolling Service Door

NOTE: For specifications, architects must choose from a variety of options. The standard choice will be shown first in plain text followed by the options shown in [brackets] (Example "Finish: Galvanized [Powder coated] [Baked enamel]"). The specifier must make the appropriate choices and delete the others (Example: "Finish: Powder coated").

GENERAL

- 1.01 SUMMARY
 - A. This section includes: [Manual] or [Electric] operated Economy Box Spring Door.
 - 1. Cycle life: Design doors of standard construction for use up to 12,000 cycles.
 - 2. Dimensions: To be a manual push-up, door must not exceed 120 ft.²
 - B. Related Sections: Related to this section, but not limited to, the following (based on Master Format 2004):
 - 1. Section 01660 Product Storage and Handling Requirements.
 - 2. Section 04220 Concrete Unit Masonry.
 - 3. Section 05120 Structural Steel.
 - 4. Section 06100 Rough Carpentry.
 - 5. Section 08310 Access Doors and Panels.
 - 6. Section 08710 Door Hardware.
 - 7. Section 09290 Gypsum Board.
 - 8. Section 09900 Paints and Coatings.
 - 9. Section 26000 Electrical.
- 1.02 REFERENCES
 - A. ASTM A 653/A 653M Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process
 - B. ASTM A 1018/A 1018M Standard Specification for Steel, Sheet and Strip, Heavy-Thickness Coils, Hot-Rolled, Carbon, Commercial, Drawing, Structural, High-Strength Low-Alloy, and High-Strength Low-Alloy with Improved Formidability
 - C. ASTM A 123 Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products
 - D. ASTM A 312 Standard Specification for Seamless, Welded, and Heavily Cold Worked Austenitic Stainless Steel Pipes
 - E. ASTM A 240 Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications
 - F. ASTM A 276 Standard Specification for Stainless Steel Bars and Shapes
 - G. ASTM B 209 Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate
 - H. ASTM B 221 Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes









1.03 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Provide manufacturer's standard details and catalog data. Provide installation instructions.
- C. Shop Drawings: Furnish shop drawings for architect's approval. Include elevation, sections, and details indicating dimensions, materials, finishes, conditions for anchorage and support of each door.
- D. Submit manufacturer's recommended operation, troubleshooting, and maintenance instructions.
- 1.04 QUALITY ASSURANCE
 - A. Manufacturer: Rolling doors shall be manufactured by a firm with a minimum of five years experience.
 - B. Single-Source Responsibility: Manufacturer shall provide doors, tracks, motors, and accessories for each type of door. Secondary components shall come from a source acceptable to the manufacturer of the primary components.
- 1.05 DELIVERY, STORAGE, AND HANDLING
 - A. Deliver materials in original packaging supplied by manufacturer with intact labels. Store materials away from harmful environmental conditions and construction.
- 1.06 WARRANTY
 - A. Door Warranty: Provide one year written warranty from date of installation against deficiencies due to defects in materials or workmanship. Installer agrees to repair or replace any defects in materials or workmanship.
 - B. Project Warranty: Refer to Conditions of the Contract for project warranty provisions.

PART 2 - PRODUCTS

- 2.01 MANUFACTURER
 - A. Manufacturer: Alpine Overhead Doors, Inc.; 8 Hulse Road Suite 1S, East Setauket, NY 11733. Telephone 800-257-4634 or 631-473-9300. Fax 631-642-0800.
 - B. Model: DAWN 4 DOOR® Rolling Service Door
- 2.02 MATERIALS
 - A. Curtain:
 - 1. Slats: Constructed of interlocking, roll-formed 4" curve [4" curve perforated] slats. (For grilles, see specs for Dawn Grille)
 - a) Material:
 - i) Galvanized steel, G90 coating exterior (G60 interior), Structural Quality Grade C, as per ASTM A 653/ A 653 M

Finish: Galvanized [Powder coated] [Baked enamel] (Minimum coating conforming with Coating Designation G-01 is required)

-OR -

ii) ASTM 240 Stainless steel 300 series

Finish: [Mill finish #2B] [#4 satin finish]

– OR –









iii) Aluminum

Finish: Mill Finish [Clear anodized] [Bronze anodized] [Black anodized]

- b) Gauge: (Per manufacturer's standard)
 - i) Galvanized/Stainless: Minimum 22 gauge as manufacturer standard [20, 18, 16 gauge].
- ii) Aluminum: Minimum 0.050" thick.
- 2. [Vision Lite panels] (for flat slats only): Provide 6" by 1 ¼" oval acrylic panes set into curtain. (Choose number and placement)
- 3. Endlocks:
 - a) Stamped, hot-dip galvanized endlocks riveted (solid rivets, minimum 3/8" thick) to each end of alternate slats to prevent lateral movement and to limit slat deflection and bending stress.
- 4. Bottom Bar: (Size dependent on dimensions per manufacturer's standard)
 - a) Extruded aluminum bottom bar
 - i) Aluminum

Finish: Mill Finish [Clear anodized] [Bronze anodized] [Black anodized]

b) [Tubular Aluminum bottom bar]

Finish: Mill Finish [Clear anodized] [Bronze anodized] [Black anodized]

- B. Guides:
 - 1. Guides shall be roll formed consisting of 13 gauge steel, steel mounting angles, expansion slotted connections, and removable curtain stops to allow for curtain maintenance without removal of guides.
 - a) Material:
 - i) ASTM A 1018/A 1018 M Steel

Finish: Gray shop prime coat [ASTM A 123 Galvanized] [baked enamel paint] [powder coated].

- C. Door Support Brackets and Mounting Plates:
 - 1. 13 gauge steel stamped brackets, welded to guides. Plate supports counterbalance assembly and forms end enclosures.
 - a) Material:
 - i) ASTM A 1018/A 1018 M Steel:

Finish: Gray shop prime coat [ASTM A 123 Galvanized] [Baked enamel paint] [Powder coated].

- D. Counterbalance Assembly: Band Spring
 - 1. Consists of flat blue spring steel wrapped around a 2" pipe shaft and mounted into a spring box.
- E. Hood:









- 1. 24 gauge steel [.040" aluminum]. Formed to fit the contour of the end brackets with reinforced top and bottom edges.
- 2. Shape: Hexagon [square] [round]
- 3. Material:
 - a) Galvanized Steel as per ASTM A 653/ A 653 M

Finish: [Baked enamel paint] [Powder coated]

– OR –

b) ASTM 240 Stainless Steel 300 Series:

Finish: [Mill finish #2B] [#4 satin finish]

- OR -

c) Aluminum

Finish: Mill Finish [Clear anodized] [Bronze anodized] [Black anodized]

- 4. [Fascia]: Galvanized [Stainless Steel] [Aluminum], provided where areas behind door hood are open. Materials and finish same as hood.
- F. Locking:
 - 1. Provide hasps and pins, prepared for padlocks on coil side. [Slide locks]
- 2.03 OPERATION:
 - A. Opening/Closing: Manual push-up [Motor Operator].
 - B. [Motor Operator]:
 - 1. Alpine Redi-Central® 115 V, 60 Hz, single phase motor.
- 2.04 Mounting:
 - 1. Interior face mounted on prepared opening.
 - 2. Interior mounted between jambs and under lintel in a prepared opening.
 - 3. Exterior face mounted on prepared opening.

PART 3 - EXECUTION

- 3.01 EXAMINATION
 - A. Verify that dimensions are correct and project conditions are in accordance with manufacturer's installation instructions; do not proceed with installation until unacceptable conditions have been corrected.
- 3.02 INSTALLATION
 - A. Install units in accordance with manufacturer's instructions.
 - B. Ensure that units are installed plumb and true, free of warp or twist, and within tolerances specified by manufacturer for smooth operation.
- 3.03 FIELD TESTING
 - A. Test doors for regular operation.









3.04 DEMONSTRATION

- A. Instruct the Owner's personnel in correct operation and maintenance of units.
- 3.05 ADJUST AND CLEAN
 - A. Clean units in accordance with manufacturer's instructions.
 - B. Restore slight blemishes in finishes in accordance with manufacturer's instructions to match original finish. Remove and provide new units where repairs are not acceptable to the Architect.

