

Certificate of Validation



Certificate No: 1874C

Expiration Date: Dec. 16, 2026

Manufacturer:
Alpine Overhead Doors, Inc

Product Identification: FEMA-TITE Steel Roll-Up Door System

Manufacturing Location(s): 8 Hulse Road East Setauket, NY 11733

Product Type: Steel Roll-Up Door System

Certified Standards: ICC 500-2014 & FEMA P361-2015.

(Series/Model = FEMA-TITE
Design Pressure = 254psf / Test Pressure = 305psf
Missile Impact = 13ft / 15lb 2x4 @ 1 00MPH
Maximum Tested Size = 20ft Width x 14ft Height
Minimum Tested Size = 3ft-6in Width x 4ft Height)

CSI Division(s): 08 39 24 - Tornado-Resistant Doors

ICS Number Code(s): 91.120.99 Other standards related to protection of and in buildings

Only products bearing the PRI-CMT Validation Program Mark will be considered as being included in good standing the Validation Program.

Issued By:

A handwritten signature in black ink, appearing to read 'Brad Grzybowski'.

Brad Grzybowski
PRI-CMT, LLC

Reviewed by:

A handwritten signature in black ink, appearing to read 'Brian Wilson'.

Brian Wilson
PRI-CMT, LLC